



**LS-26-01  
PADRE BOULEVARD MEDIAN IMPROVEMENTS**

**Addendum Issue Date: February 4, 2026**

**BID DUE DATE:  
Monday, February 9th, 2026**

**BID DUE TIME:  
3:00 P.M. C.S.T.**

**\*\*\*\*\*SEE ATTACHED CHANGES\*\*\*\*\***

**Bid is amended as follows:**

**1. Project Schedule**

- a. Project schedule and construction days has been changed to 90 calendar days after Notice To Proceed.

**2. Demolition**

- a. All median islands to be demoed to 6" depth below top of curb and 12" depth in middle planting areas. 6" depth areas to receive filter fabric, boulders and washed gravel and 12" depth areas to receive topsoil/compost mix and shredded hardwood mulch as specified.
- b. During demo, contractor to adjust light fixture locations to gravel areas. PVC pieces around light fixtures to be removed.
- c. Existing irrigation valve boxes shall be relocated to gravel areas and painted to match gravel (beige/gray lid covers).
- d. Existing irrigation bubblers on palms to be removed and any laterals that connect bubblers back to the mainlines.

**3. Concrete Pads**

- a. Concrete pads for planters shall be 6" thick, 3000 psi, welded wire mesh and fiber mesh reinforced, with Sika Color-100 P (Butterfield) Uni-Mix color (Color to be U14-Pewter). 1 Bag per cubic yard of concrete.

**4. Pavers (Alternate No. 1)**

- a. Alternate No. 1 shall include lifting and resetting pavers that are depressed and replace pavers that are damaged. Reset pavers on clean sand and compact with plate compactor to be flush with top of curb and adjacent pavers. See Alternate No. 1 on bid form.

## 5. Revised Plans & Bid Form

- a. See attached revised sheets L1.00-L2.07 and revised bid form.

---

Signature, Acknowledge Add. #1

---

Date

---

Company Name (Print/Type Name)

**END OF ADDENDUM NO. 1**



Scott Pajeski, ASLA  
SSP Design, LLC

All Addenda issued in respect to this project shall be considered official changes to the original bidding documents. It shall be the Respondent(s) responsibility to ensure that all Addenda have been received. Furthermore, respondents are advised that they must recognize, comply with, and attach a signed copy of each Addenda which shall be made part of their Bid Submittal. Respondent(s) signature on Addenda shall be interpreted as the vendor's "recognition and compliance to" official changes as outlined by SPI and as such are made part of the original bidding documents.